



State Water Resources Control Board

Division of Drinking Water

January 22, 2015 Certified Mail/Return 7012 3460 0003 1113 1571

City of Orland – Haigh Field Industrial Park 815 5th Street Orland, CA 95963

Attention: Forrest Marston, Public Works Supervisor

Subject: Public Water System No. 1105003 - Citation No. 21-15C-004 for Lead and

Copper Rule monitoring violation.

It has come to our attention that the Haigh Field Industrial Park water system failed to provide six month lead and copper samples in the year 2011, according to the Lead and Copper Rule (LCR). Consequently, the Division of Drinking Water has issued the enclosed Citation for Noncompliance (Citation) to the water system. The enclosed Citation includes directives for corrective action and public notification.

Section 116577 of the California Safe Drinking Water Act provides for the division to be reimbursed by the public water system for costs incurred for preparing and issuing a citation. The billing rate is approximately \$128 per hour. At this time, we have spent approximately one hour preparing this violation. You will receive a bill for these costs, typically by September 1st, from the Sacramento office.

If you have any questions please call Paul Rowe at (530) 224-4866 or contact me directly at (530) 224-4861.

Reese B. Crenshaw, P.E. Valley District Engineer DRINKING WATER FIELD OPERATIONS BRANCH

Enclosures

1	Citation No	o. 21-15 C -004	ļ					
2								
3	STATE WATER RESOURCES CONTROL BOARD							
4	DIVISION OF DRINKING WATER							
5								
6	Public Wat	ter System:	Haigh Field Industrial Park					
7	Water System No.:		1105003					
8								
9	To:	City of Orla	nd .					
10		Attn: Forre	st Marston, Public Works Supervisor					
11	815 5 th Street							
12	Orland, CA 95963							
13								
14	Issued:	January 22,	2015					
15		VIA CERTIF	FIED MAIL					
16								
17								
18	,	C	CITATION FOR NONCOMPLIANCE					
19		With '	Title 22 California Code of Regulations					
20			Sections 64675					
21								
22	Section 116	6650 of the 0	California Health and Safety Code (CHSC) authorizes the					
23	issuance of	a citation for	failure to comply with a requirement of the California Safe					
24	Drinking W	ater Act (CH	SC, Division 104, Part 12, Chapter 4, commencing with					
25	Section 116	270), or any r	egulation, standard, permit, or order issued thereunder.					



26

The State Water Resources Control Board (hereinafter "Board"), acting by and through its Division of Drinking Water (hereinafter "Division") and the Deputy Director for the Division, hereby issues a citation to Haigh Field Industrial Park for failure to comply with Section 64675.5, Title 22, of the California Code of Regulations (CCR).

APPLICABLE AUTHORITIES

Section 116650 of the CHSC states:

(a) If the division determines that a public water system is in violation of this chapter or any regulation, permit, standard, citation, or order issued or adopted thereunder, the division may issue a citation to the public water system. The citation shall be served upon the public water system personally or by certified mail. Service shall be deemed effective as of the date of personal service or the date of receipt of the certified mail. If a person to whom a citation is directed refuses to accept delivery of the certified mail, the date of service shall be deemed to be the date of mailing.

(b) Each citation shall be in writing and shall describe the nature of the violation or violations, including a reference to the statutory provision. standard, order, citation, permit, or regulation alleged to have been violated.

23

(c) A citation may specify a date for elimination or correction of the condition constituting the violation.

26

25



(d) A	citation	may	include	the	assessment	of a	penalty a	as	specified	in
S	ubdivisio	n (e).								

(e) The division may assess a penalty in an amount not to exceed one thousand dollars (\$1,000) per day for each day that a violation occurred, and for each day that a violation continues to occur. A separate penalty may be assessed for each violation.

Section 64675.5, Title 22, of the CCR states in relevant part:

- (a) A system shall conduct standard tap sampling for two consecutive periods; thereafter, tap sampling frequency may be reduced pursuant to section 64675 (General Requirements for Tap Sampling for Lead and Copper) as follows:
 - (1) If a system has 90th percentile levels that do not exceed 0.005 mg/L for lead and 0.65 mg/L for copper for two consecutive periods, it may reduce the sampling to once every three years at the reduced number of sites.

STATEMENT OF FACTS

The Haigh Field Industrial Park (hereinafter "Water System") is classified as a non-transient non-community water system serving approximately 30 people. Because the Water System began initial sampling in June of 2011, it was required to collect



1	additional samples in December of 2011. The Water System failed to collect lead and					
2	copper samples at the end of the six month period in December of 2011.					
3						
4	DETERMINATIONS					
5	The Division has determined that the Water System violated Section 64675.5(a)(1),					
6	Title 22, of the CCR, in that the Water System failed to collect six month samples in					
7	December of 2011.					
8						
9	DIRECTIVES					
10	The Water System is hereby directed to take the following actions:					
11						
12	1. Comply with Section 64675.5, Title 22, of the CCR in all future monitoring					
13	periods.					
14						
15	2. Conduct lead and copper monitoring from customer's taps in June, July,					
16	August, or September of 2015. Thereafter, triennial sampling may begin.					
17	Samples shall be collected in accordance with the Lead and Copper Rule					
18	sampling per Title 22, Section 64677. The analytical results must be reported					
19	to the Division by the 10 th day of the month following the month in which the					
20	analyses were completed.					
21 22						
23	3. The Water System shall provide public notification (by inclusion in the 2014					
24						
	Consumer Confidence Report) of the failure to sample lead and copper, as					
25	required by the Lead and Copper regulations.					
26						



CITATION NO. 21-15C-003 Issued: January 22, 2015

	n e e e e e e e e e e e e e e e e e e e					
1	All documents required by this Citation to be submitted to the Division shall be					
2	submitted to the following address:					
3						
4	Reese B. Crenshaw, P. E.					
5	Valley District Engineer					
6	Drinking Water Field Operations					
7	Division of Drinking Water					
8	State Water Resources Control Board					
9	364 Knollcrest Drive, Suite 101					
10	Redding, CA 96002					
11	(530) 224-4800					
12						
13	Nothing in this Citation relieves the Water System of its obligation to meet the					
14	requirements of Health and Safety Code, Division 104, Part 12, Chapter 4 (California					
15	Safe Drinking Water Act), or any regulation, permit, standard or order issued or					
16	adopted thereunder.					
17						
18	The Division reserves the right to make such modifications to this Citation, as it may					
19	deem necessary to protect public health and safety. Such modifications may be					
20	issued as amendments to this Citation and shall be effective upon issuance.					
21						
22						
23	FURTHER ENFORCEMENT ACTION					
24	The California SDWA authorizes the Board to: issue citation with assessment of					
25	administrative penalties to a public water system for violation or continued violation of					
26	the requirements of the California SDWA or any permit, regulation, permit or order					
7	issued or adopted thereunder including, but not limited to, failure to correct a violation					



CITATION NO. 21-15C-003 Issued: January 22, 2015

identified in a citation or compliance order. The California SDWA also authorizes the Board to take action to suspend or revoke a permit that has been issued to a public water system if the system has violated applicable law or regulations or has failed to comply with an order of the Board; and to petition the superior court to take various enforcement measures against a public water system that has failed to comply with violates an order of the Board. The Board does not waive any further enforcement action by issuance of this citation. **PARTIES BOUND** This Citation shall apply to and be binding upon the System, its officers, directors,

agents, employees, contractors, successors, and assignees.

12

13

14

15

16

1

2

3

4

5

6

7

8

9

10

11

SEVERABILITY

The directives of this Citation are severable, and Haigh Field Industrial Park shall comply with each and every provision thereof notwithstanding the effectiveness of any other provision.

17

18

19 20 21

22

23

Reese B. Crenshaw, P.E., District Engineer

Valley District

Drinking Water Field Operations Branch



